


**NOTE:**

AN ACCEPTED ALTERNATE IS P&L CONCRETE PRODUCTS PRECAST GREASE TRAP WITH ADDED SAMPLE CHAMBER ON OUTLET END AS SHOWN ON THIS DRAWING.

**PLAN VIEW**

**NOTE:**

TRAFFIC LIDS TO BE INSTALLED IN TRAFFIC AREAS



**SECTION A-A**

CAPACITY GALLONS	DIMENSIONS							COVER SIZE	METAL COVERS	PIPE SIZE
	A	B	C	D	E	F	G			
510	3'-0"	9'-6"	3'-0"	2'-6"	1'-6"	4 1/2"	1'-6"	2'-10"x3'-4"	1/4" STEEL PLATE	4"
866	3'-5"	10'-3"	4'-0"	2'-5"	2'-0"	0'-6"	1'-9"	3'-10"x3'-10"	3/8" ALUMINUM PLATE	4"
1260	4'-0"	12'-6"	4'-0"	3'-6"	2'-0"	0'-6"	2'-0"	3'-10"x4'-4"	3/8" ALUMINUM PLATE	4"

APPROVED BY CITY COUNCIL  
RESOLUTION NO. 2006-284


APPROVED BY THE CITY ENGINEER:

*Richard D. Ull*

**SEWERS**

**GREASE & OIL INTERCEPTOR**

PUBLIC WORKS  
DEPARTMENT



CITY of MODESTO

DETAIL NO.  
**512**